



To,
Baridih High School
Tube Colony
Baridih
Jamshedpur-17

WMD/LAB/TL-35/ 605/25

Date: 04.09.25

Sub : Drinking Water Quality of your Institution

Dear Sir/Madam

Water samples were received on 2.09.25 for analysis of the water quality at our laboratory. The water quality of the samples was found to be satisfactory. Chemical & Bacteriological analysis report is appended below.

Chemical & Bacteriological analysis report.

Sl. No.	Parameters	Source	Standards / Norms	
		Drinking water tap	World Health Organization (WHO)	Bureau of Indian Standards (BIS)
1	Turbidity (NTU)	1.0	≤ 1.0	≤1.0(Acceptable) ≤5.0 (Permissible)
2	pH	7.4	6.5-8.5	6.5-8.5
3	Free chlorine(mg/l)	0.2	≥ 0.2	≥0.2
4	Total Coliforms/100ml	Absent	Absent	Absent
5	E. coli/100ml	Absent	Absent	Absent

Thank you and we always assure you of our best services.

Yours Sincerely,

Sr Manager/Manager
Town Laboratory, Waterworks.
Water & Wastewater Services.

TATA STEEL UTILITIES AND INFRASTRUCTURE SERVICES LIMITED
(Formerly Jamshedpur Utilities & Services Company Limited)

Registered Office Sakchi Boulevard Road Northern Town Bistupur Jamshedpur 831 001 India
Tel 91 657 6652101 Fax 91 657 2424219
Corporate Identity Number U45200JH2003PLC010315
Website www.tatasteeluisl.com

S. Haldas
Principal
Baridih High School
Tube Colony, Baridih,
Jamshedpur, Jharkhand